



AHENSIAŃ PRUTEKSIŃ LINAĀĀ GUĀHAN

LOURDES A. LEON GUERRERO, GOVERNOR OF GUAM • JOSHUA F. TENORIO, LIEUTENANT GOVERNOR OF GUAM
WALTER S. LEON GUERRERO, ADMINISTRATOR

**NOTICE OF VIOLATION
GREASE TRAP**

Notice of Violation issued to:

Control Number: WFC 2019-002

Business/restaurant name: AT VALENTINUS RESTAURANT AND SPORT LOUNGE

Owner/manager name: FLORES, EDWIN JOSEPH P.

Email: _____ Phone: 727-0082

Mailing Address: 138 IFIL CT LIQUAN TERRACE DEDEDO, GUAM 96929

Physical address/building name: LOT 5166-22-LS 14-SEC 2 #244 HARMON INDUSTRIAL PARK

Description of Violation:

GEPA staff conducted an inspection of the premises described above and found the following deficiencies:

1) GREASE TRAP HAS A LOT OF F.O.G. 2) ALSO HAVE PUMPER COMPANY CHECK IF GREASE TRAP IS WORKING PROPERLY

The facts described above indicate a violation of the Guam Individual Wastewater Disposal System Regulations, 22 GAR §12118(f): "In order to be effective, grease traps must be operated properly and cleaned regularly to prevent the escape of appreciable quantities of grease. The frequency of cleaning at any given installation can best be determined by experience based on observation. Generally, cleaning should be done when 75% of the grease- retention capacity has been reached. At restaurants, pumping frequencies range from once a week to once every 2 or 3 months."

Corrective Actions

Within 5 calendar days, complete the following corrective actions:

- Have the grease trap pumped by a GEPA licensed wastewater pumping company.
- Repair or replace the defective grease trap or grease trap component(s).
- Clean and disinfect the area where wastewater and grease was spilled.

If the corrective actions are not completed within the specified time, this matter may be referred to the Office of the Attorney General for appropriate action. Any person who violates this regulation may be charged with a misdemeanor and subject to a fine not to exceed \$1000 per violation per day.

Ongoing: you must maintain the grease trap by having it pumped at a frequency necessary to prevent further violations. Keep all pumping receipts and make them available for GEPA inspection upon request. You should keep all pumping receipts for a period of at least 12 months.

Inspector and Recipient Signature

Inspector Name: Heley R. Gumataotao

Title: INSPECTOR

Inspector Signature: [Signature]

Received by: [Signature]

Date and time of inspection: 9/13/2019 10:04 AM

PRINT NAME AND SIGN

Questions regarding this matter should be referred to Guam EPA at 300-4751/52/53.



AHENSIAN PRUTEKSION LINA'LA GUĀHAN

**LOURDES A. LEON GUERRERO, GOVERNOR OF GUAM • JOSHUA F. TENORIO, LIEUTENANT GOVERNOR OF GUAM
WALTER S. LEON GUERRERO, ADMINISTRATOR**



Grease Trap at Former Marina Rest. DBA: AT Valentinus Rest. and Sport Lounge Harmon Industrial Park. 9/13/2019

TERMS & CONDITIONS

ACCOUNTS WILL BE BILLED 15 DAYS AFTER SERVICE. DELINQUENT ACCOUNTS WILL BE CHARGED 2% PER MONTH ON THE OVERDUE BALANCE. IN THE EVENT THIS ACCOUNT IS REFERRED OVER FOR COLLECTION OR COURT ACTION, CUSTOMER AGREES TO PAY FOR THE MAULEG'S ATTORNEY FEE, ANY COLLECTION, AND OR COURT COSTS.

RECOMMENDATIONS

Todo Mauleg



PORTA TOILETS
SEPTIC PUMPING
PIPE SNAKING
LEACH FIELD REINVENTATION
PLUMBING

Job No. 67066
JOB PHONE
JOB LOCATION
CITY
OCCUPANT'S NAME
DATE
PICK UP
RES
JOB

NAME: *Manning Estimating*
ADDRESS: *Heather Trinchental Paul*

DESCRIPTION OF WORK

** Minor plumbing of water trap parts
* Trap change including*

| | |
|-------------|---------------|
| Sewer | Septic |
| Catch Basin | Leach Field |
| Grease Trap | Laundry Tub |
| Toilet | Urinal |
| Sink | Dispenser |
| Bath Tub | Basin |
| Other | Laundry/Drain |
| Stoppage At | Total Run |

| DATE | SERVICEMAN | HOURS | RATE | AMOUNT | MATERIAL |
|----------------|---------------|-------|------|--------|----------|
| <i>7/18/04</i> | <i>Wilson</i> | | | | |

I hereby authorize the work described above and agree to the terms and conditions as stated being now forwared as agreed and delineated plumbing repairs, piping and appurtenances may no longer be available. I agree to hold Mauleg harmless for any damage or destruction to cause as a result of conventional repair work.

X SIGNATURE: *[Signature]* EDWIN FLEWES

PLEASE PAY FROM THIS INVOICE. NO STATEMENT RENDERED.

- Special Cuts/Tools: Exp Shark Spade Auger
- Power Jetting: Power Jetting
- Flow: Light Medium Heavy