



GUAM ENVIRONMENTAL PROTECTION AGENCY • AHENSIAN PRUTEKSIÓN LINA'LA' GUÁHAN
LOURDES A. LEON GUERRERO • GOVERNOR OF GUAM | JOSHUA F. TENORIO • LIEUTENANT GOVERNOR OF GUAM
MICHELLE C. R. LASTIMOZA • ADMINISTRATOR

MAY 20 2026

Jack Taitague
Project Director
Guam International Country Club
495 Batulo Rd.
Dededo, Guam 96929

RE: Notice of Violation, Order of Compliance, and Administrative Penalty Order UST26-002,
Guam International Country Club

Hafa Adai Mr. Taitague:

You are hereby advised that this Notice of Violation/Order of Compliance/Administrative Penalty Order UST26-002 is being issued to Guam International Country Club (GICC).

The Guam Environmental Protection Agency (Guam EPA) is charged with the responsibility of implementing and enforcing the Underground Storage of Regulated Substances Act (USRSA), as amended, Chapter 76 of Title 10, Guam Code Annotated (GCA), Public Law No. 32-195, and the Guam Underground Storage Tank Regulations, Chapter 50 of Title 22, Guam Administrative Rules and Regulations (GAR).

The Guam EPA Administrator shall enforce rules and regulations governing UST design, construction, installation, release detection and inventory control, compatibility, record maintenance, reporting, corrective action closure, and financial responsibility in order to enforce this Chapter. 10 GCA §76104(d)

The Guam EPA Administrator shall issue and enforce orders necessary to ensure compliance with 10 GCA Chapter 76 and any rules and regulations enacted pursuant 10 GCA Chapter 76, including “- administrative penalty orders and orders requiring necessary or appropriate corrective action -”. 10 GCA §76104(g)

On March 19, 2026, representatives from the Guam EPA conducted an UST Inspection at GICC located at 495 Batulo Road, Dededo. The UST inspection was conducted with the assistance of the Cleaning Contractors who were present and helped open the UST systems to verify compliance with Title 10 GCA Chapter 76 and Title 22 GAR Chapter 50.



GUAM EPA | 17-3304 Mariner Avenue Tiyan Barrigada, Guam 96913-1617 | Tel: (671) 588.4751 | Fax: (671) 588.4531 | epa.guam.gov
ALL LIVING THINGS OF THE EARTH ARE ONE • MANUNU TODU I MANLÁLA'LA'

 Like and follow [guamepa](https://www.instagram.com/guamepa)

The compliance inspection started with an In-Brief discussion about the UST systems and the reason for the inspection. A walk through of the areas over UST#1 a 1,000 gallon gasoline tank and UST#2 a 8,000 gallon diesel tank located at the GICC Generator Building and fuel dispenser; and UST#3 a 2,500 gallon gasoline tank located at the GICC Maintenance Building. The walk through included inspecting sites' sump and fill point areas, the emergency generator room, and to the automatic tank gauges (ATG) located inside the generator building and maintenance building respectively. Inspectors then requested the facilities records of release detection for the UST system, any testing reports for the tank, piping, sumps, spill buckets, overfill equipment, ATG certification, and Operator Training. During the inspection there was no power to the Maintenance Building UST system and there were no records readily available. An Out-Brief of our findings was provided throughout the inspection. The findings of the inspection determined the following deficiencies are the basis for this notice of violations.

NOTICE OF VIOLATIONS

Based on the deficiencies cited, GICC is in violation of the following sections of Chapter 50 of Title 22 GAR.

1. "The results of any sampling, testing, or monitoring must be maintained for at least three (3) years..." 22 GAR §50406(a)(2)
 - **GICC failed to maintain results and/or records of monitoring/testing of functionality tests for the release detection mechanism.**
2. "All UST system owners and operators must maintain records in accordance with § 50305 demonstrating compliance with all applicable requirements of this subchapter." 22 GAR §50406(a)
 - **GICC failed to maintain records for the tank and piping release detection.**
3. "Owners and operators of UST systems with spill and overfill prevention equipment and containment sumps used for interstitial monitoring of piping must meet these requirements by October 13, 2018 to ensure the equipment is operating properly and will prevent releases to the environment." 22 GAR §50306(a)
 - **GICC failed to maintain results and/or records of periodic testing of spill prevention and containment equipment.**
4. "...owners and operators must conduct walkthrough inspections that, at a minimum, check the following equipment as specified below: (1) Every thirty (30) calendar days...Annually..." 22 GAR §50307(a)(1)(2)



- **GICC failed to maintain records of monthly and annual walkthrough inspections for the UST system.**

- 5. "Owners and operators of underground storage tank systems must maintain a list of designated Class A, Class B, and Class C operators and maintain records verifying that training and retraining, as applicable, have been completed, in accordance with § 50305..." 22 GAR §501006

- **GICC failed to maintain records verifying the training of designated Class A/B/C operators.**

Guam International Country Club has the option to choose between two courses of action to bring the facility back into compliance.

ORDER OF COMPLIANCE FOR UST OPERATION

Based on the violations cited above, Guam EPA hereby requires GICC to perform the following corrective action to ensure compliance with 10 GCA Chapter 76 and 22 GAR Chapter 50 if the facility will continue use of the Underground Storage Tanks:

1. GICC shall retain the services of a certified technician(s) to conduct diagnostic and systems servicing on the leak detection system, to determine and certify that the system is operational and functioning per manufacture specification standards and regulatory requirements. GICC shall submit copies of the results of the testing and any repairs to Guam EPA within forty-five (45) calendar days.

2. GICC shall submit copies of the release detection records to Guam EPA each month for the next three (3) months.

3. GICC shall conduct testing of spill and overflow prevention and containment sumps.

4. GICC shall conduct periodic operation and maintenance walkthrough inspections in accordance with 22 GAR §50307. (See attached example checklist: Petroleum Equipment Institute Recommended Practice RP 900, Appendix A-2 and A-3). GICC shall keep these checklist records on file.

5. GICC shall designate and have these persons train for Class A/B/C Operators from an approved and authorized entity.

6. GICC shall obtain their Underground Storage Tank Operating Permit.



Nothing in this Order of Compliance limits the ability of Guam EPA to enforce any and all provisions of applicable Guam laws and regulations. Guam EPA does not waive any rights or remedies available to it. Failure to comply with this Compliance Order may subject you to additional administrative, civil or criminal penalties.

However, prior to the inspection Guam EPA made contact to obtain access to the facility which was found to be closed for business. Furthermore, a contractor retained by GICC to perform cleaning operations stated that the three (3) USTs have not been in use for an extended period and that GICC intended to permanently close them. If GICC has made the determination to close the three (3) USTs that are currently out of regulatory compliance, GICC is hereby directed to immediately undertake the following actions:

1. GICC must notify the agency in writing of their intent to permanently close or make the change-in-service, unless such action is in response to a confirmed release. The required assessment of the excavation zone under § 50703 must be performed after notifying the agency but before completion of the permanent closure or change-in-service.
2. GICC must notify the agency of the exact date that the work will occur at least seven (7) calendar days before excavation work for a permanent closure or change-in-service.
3. GICC will empty and clean the USTs and tank systems by removing all liquids and accumulated sludge.
4. GICC will remove the USTs from the ground and conduct a site assessment in accordance with § 50703.
5. Within thirty (30) calendar days of completing a permanent closure or change-in-service, GICC must submit a notification to the agency indicating completion of the closure.
6. Before permanent closure or a change-in-service is completed, GICC must measure for the presence of a release where contamination is most likely to be present at the UST site.

Nothing in this Order of Compliance limits the ability of Guam EPA to enforce any and all provisions of applicable Guam laws and regulations. Guam EPA does not waive any rights or remedies available to it. Failure to comply with this Compliance Order may subject you to additional administrative, civil or criminal penalties.

ADMINISTRATIVE PENALTY ORDER

In addition to this Notice of Violation/Order of Compliance, the Administrator of Guam EPA, pursuant to 10 GCA § 76124 (a), hereby imposes an administrative penalty.



The maximum administrative penalty for Leak Detection and Record Maintenance is sixteen thousand dollars (\$16,000.00) for each tank for each day of each violation.

GICC did not maintain a leak detection system that identifies releases dangerous to human health and the environment, and did not maintain systematic and complete records to demonstrate compliance with 10 GCA Chapter 76. The Administrator hereby assesses a penalty of:

- \$12,287.00 for failure to maintain results and/or records of monitoring/testing of functionality tests for the release detection mechanism, in violation of 22 GAR §50406(a)(2);
- \$5,029.00 for failure to maintain records for tank and piping release detection, in violation of 22 GAR §50406(a);
- \$5,029.00 for failure to maintain results and/or records of periodic testing of spill prevention and containment equipment, in violation of 22 GAR §50306(a);
- \$5,029.00 for failure to maintain records of monthly and annual walkthrough inspections for the UST system, in violation of 22 GAR §50307(a)(1)(2); and
- \$12,287.00 for failure to maintain records verifying the training of designated Class A/B/C operators, in violation of 22 GAR §501006.

You are presumed under the law to be able to pay the penalty under 10 GCA Chapter 76.

The penalty amounts are due and owing fifteen (15) calendar days from the date of receipt of this Administrative Penalty Order. The payment due date will be stayed upon the timely filing of a Notice of Intent to Appeal/Notice of Defense. Failure to comply with this Administrative Penalty Order may subject you to additional administrative penalties or civil or criminal actions.

NOTICE OF RIGHT TO APPEAL

You may file within fifteen (15) calendar days of the date of receipt of this Notice of Violation/Order of Compliance/Administrative Penalty Order, a Notice of Intent to Appeal also known as a Notice of Defense with the Guam EPA's Board of Directors, setting forth in such Notice of Intent to Appeal/Notice of Defense, a verified petition outlining the legal and factual bases for such an appeal. A copy of the Notice of Intent to Appeal/Notice of Defense is attached for your convenience.

Unless a written request for a hearing signed by or on behalf of the person, agency or business entity named above in this Notice of Violation/Order of Compliance/Administrative Penalty Order is hand delivered or mailed to Guam EPA within fifteen (15) calendar days after the Notice of Violation/Order of Compliance/Administrative Penalty Order was personally served on you or mailed to you, Guam EPA may proceed upon the Notice of Violation/Order of Compliance/Administrative Penalty Order without a hearing.



A request for hearing may be made by delivering the enclosed form entitled "Notice of Intent to Appeal also known as a Notice of Defense", or by delivering a notice of defense as provided in 5 GCA §9205, to the following address:

Guam Environmental Protection Agency Board of Directors
c/o Administrator
Attn: Air & Land Division
Guam Environmental Protection Agency
Building 17-3304 Mariner Avenue. Tiyan
Barrigada, Guam 96913

If you file a Notice of Intent to Appeal/Notice of Defense, the Guam EPA's Board of Directors shall hold a public hearing, not more than sixty (60) calendar days after receipt of such Notice of Intent to Appeal/Notice of Defense, at which time you may appear and present evidence in person or through counsel in support of this petition.

Failure to file a Notice of Intent to Appeal and Verified Petition within the period specified above will constitute a waiver of your right to a hearing. If you waive your rights to a hearing the Order of Compliance and Administrative Penalty Order will become final, and Guam EPA may proceed upon the Orders without a hearing and without further notice to you.

Should you have any question(s) concerning the technical aspects of this letter, please contact the Hazardous Waste Management Program at (671) 588-4711/51.

Sincerely,


MICHELLE C. R. LASTIMOZA
Administrator

Enclosures: Notice of Defense
PIE Checklists

ecc: Mr. Carl Goldstein, USEPA Region 9, Guam Program Manager
Ms. Michael Cosson., USEPA Region 9, UST/LUST Program Manager
Mr. Glenn San Nicolas, Guam EPA, Acting Deputy Administrator
Ms. Angela Camacho, Chamorro Land Trust Commission, Acting Administrator Director
Ms. Geri Santos, Power Solutions, Chief Administrative Officer
Chrono/HWMP file



**NOTICE OF INTENT TO APPEAL
(AKA NOTICE OF DEFENSE)**

I, _____, have received your Notice of Violation, Order of Compliance and/or Administrative Penalty Order dated _____, charging me for violations and/or imposing penalties and/or other orders, and I wish to:
(Please check appropriate sections)

- A. Request for a hearing and**
 - 1. Object to the accusation on the ground that it does not state acts or omissions upon which the Agency can proceed.
 - 2. Object to the form of the accusation on the ground that it is so indefinite or ambiguous that I cannot identify the infraction or prepare my defense.
 - 3. Wish to prepare new matter in my defense.
 - 4. Admit to the accusation in part.
- B. Admit to the accusation in whole.**
- C. Verified Petition: Under penalty of perjury I hereby declare that the following constitutes my legal and factual basis for this appeal:**

[please continue on blank sheet of paper if more space is needed and attach to this paper]

My mailing address is:

SIGNATURE

DATE

GUAM EPA CASE NO.: UST26-002

Appendix A-1: SAMPLE FORM FOR DAILY UST SYSTEM INSPECTION CHECKLIST

Go to www.pei.org/RP900 for an electronic version of this form

DAILY UNDERGROUND STORAGE SYSTEM INSPECTION CHECKLIST	
Facility ID#	Date
Facility Name/Address	Level I Qualified Person Signature
If any problem is found, contact:	Contact information:

Category	Description	PEIRP900	Tank 1	Tank 2	Tank 3	Tank 4
Leak Detection		6.4				
Automatic Tank Gauge (ATG)	The power is on	6.4.1.1				
	There are no warning or alarm lights blinking or lit	6.4.1.2				
	There is a liquid measurement for each tank and the reading appears accurate	6.4.1.3				
	The printer has paper and is in working condition	6.4.1.4				
Electronic Leak-Detection Monitor	The power is on	6.4.2.1				
	There are no warning or alarm lights blinking or lit	6.4.2.2				
Mechanical Lime-Leak Detector	No customers have complained about slow flow	6.4.3.1				
	Inventory records are reconciled daily and daily variance is within the guidelines set by the facility owner	6.4.4.1				
Tank Fill Area		6.5				
Fill Cover	Fill cover present, not broken or damaged	6.5.1.1				
	Fill covers are identified by color and located on the correct tank	6.5.1.2				
	No dirt, trash, water, or product in the spill-containment manhole	6.5.2.1				
Spill Containment Manhole (Spill Bucket)	No cracks, bulges or holes in the spill-containment manhole	6.5.2.2				
	Below-grade containment manhole properly latched (if present)	6.5.2.3				
	Below-grade containment manhole contains oil absorbent material	6.5.2.4				
Fill Pipe	Fill cap in good condition, seals tightly	6.5.3.1				
	No obstruction inside the fill pipe	6.5.3.2				

DESCRIBE ANY DEFICIENCIES HERE:

Instructions: Mark each tank where no problem is observed with a checkmark: ✓ If certain equipment is not required and / or not present, mark checklist in the N/A column. If a defect is found, mark the checklist with an "X," describe the problem in the "DEFICIENCIES" section, and notify the appropriate person. Refer to the section in the PEI Recommended Practices on UST system equipment inspection listed in the 'PEIRP900' column for additional information. Refer to PEI RP900 Recommended Practices for Inspection and Maintenance of Motor Fuel Dispensing Equipment, for inspection procedures that apply to fuel dispensing equipment.

Appendix A-2: SAMPLE FORM FOR MONTHLY UNDERGROUND STORAGE SYSTEM INSPECTION CHECKLIST – PAGE 1

Go to www.pei.org/RF900 for an electronic version of this form

MONTHLY UNDERGROUND STORAGE SYSTEM INSPECTION CHECKLIST			
Facility ID#	Facility Name/Address	Level II Qualified Person Signature	Date
If any problem is found, contact:		Contact information:	

Category	Description	PEI/RF900	N/A	Tank 1	Tank 2	Tank 3	Tank 4
Daily Inspections	Complete daily checklist and compare to previously completed daily checklists	7.4.1					
Leak Detection Recordkeeping	Circle method of tank leak detection: ATG, CIM, SIR, IC, GWM, SVM, MIMT Circle method of piping leak detection: CIM, MPLT, SIR, GWM, SVM, MIMP	7.5					
Automatic Tank Gauge (ATG)	Passing tank test report printed and properly filed	7.5.1.1					
Continuous Interstitial Monitoring (CIM)	Sensor status report printed and properly filed	7.5.2.1					
Monthly Piping Leak Test (MPLT)	Passing piping leak-test report printed/documented and properly filed	7.5.3.1					
Statistical Inventory Reconciliation (SIR)	This month's inventory analyzed; last month's results passed and available for inspection	7.5.4.1					
Inventory Control (IC)	Inventory reconciled and within the company or regulatory standard	7.5.5.1					
Manual Groundwater (GWM) or Soil Vapor Monitoring (SVM)	Wells sampled and results pass	7.5.6.1					
Manual Interstitial Monitoring for Tanks (MIMT)	Steel tank: interstitial space checked and found dry	7.5.7.1					
	Fiberglass tank: interstitial space checked and found dry	7.5.7.2					
	Fiberglass tank: level of monitoring fluid within normal range	7.5.7.3					
Manual Interstitial Monitoring for Piping (MIMP)	For steel and fiberglass tanks, vacuum level is within tolerances	7.5.7.4					
	Tank-top sump inspected and no liquid found	7.5.8.1					
All Tanks							
Grade-Level Covers	All covers present, in good condition, sealed firmly on the correct tank	7.6.1.1					
Spill-Containment Manhole	Drain valve in spill-containment manhole in good condition	7.6.2.1					
Drop Tube	Standard drop tube smooth, no ragged edges, in good condition	7.6.3.1					
	Top edge of coaxial drop tube smooth, round, slightly below the top edge of the fill pipe	7.6.3.2					
Tank Gauge Stick	Tank gauge stick can be clearly read, is not warped or broken	7.6.4.1					
Check for Water	No water present in the tank	7.6.5.1					
Tank Vents	Vent cap present, vent pipe solidly supported and vertical	7.6.6.1					

Appendix A-2: SAMPLE FORM FOR MONTHLY UNDERGROUND STORAGE SYSTEM INSPECTION CHECKLIST - PAGE 2

Go to www.pei.org/RP900 for an electronic version of this form

Category	Description	PEI/RP900	N/A	Tank 1	Tank 2	Tank 3	Tank 4
Stage I Vapor Recovery		7.7					
	Cover present, colored orange, seated firmly at grade, not broken, cracked or chipped	7.7.1.1					
	If spill-containment manhole is present, no dirt, trash, water, or product	7.7.1.2					
	If spill-containment manhole is present, no cracks, bulges, or holes	7.7.1.3					
	Vapor recovery cap present, seals tightly	7.7.1.4					
	Poppet of vapor recovery adaptor seals tightly	7.7.1.5					
Observation and Monitoring Wells		7.8					
	Observation well cover is properly identified and secured	7.8.1.1					
Corrosion Protection		7.9					
	Record volt and amp readings, readings consistent with previous months	7.9.1.1					
	Record hour meter reading (if present). Reading increases by about 700 hours each month	7.9.1.2					

DESCRIBE ANY DEFICIENCIES HERE:

Instructions: Mark each tank where no problem is observed with a checkmark: ✓
 If certain equipment is not required and / or not present, mark checkmark in the N/A column.
 If a defect is found, mark the checklist with an "X," describe the problem in the "DEFICIENCIES" section, and notify the appropriate person.
 Refer to the section in the PEI Recommended Practices on UST system equipment inspection listed in the 'PEI/RP900' column for additional information. Refer to PEI RP500, *Recommended Practices for Inspection and Maintenance of Motor Fuel Dispensing Equipment*, for inspection procedures that apply to fuel dispensing equipment.

Appendix A-3: SAMPLE FORM FOR ANNUAL UNDERGROUND STORAGE SYSTEM INSPECTION CHECKLIST – PAGE 1

Go to www.pei.org/RP900 for an electronic version of this form

ANNUAL UNDERGROUND STORAGE SYSTEM INSPECTION CHECKLIST			
Facility ID#	Facility Name/Address	Qualified Technician Signature	Date
If any problem is found, contact:		Contact information:	

Category	Description	PEURP900	N/A	Tank 1	Tank 2	Tank 3	Tank 4
Monthly Inspections	Complete monthly checklist and compare to previously completed monthly checklists	8.4.1					
	Monthly inspections reviewed and found adequate	8.4.2					
Submersible Turbine Pump (STP)	Junction box(es) sealed, not corroded; seal-offs present; intrinsically safe wiring in good condition	8.5					
	Mechanical line-leak detector properly vented, vent tube not kinked or twisted	8.5.1.1					
	Mechanical line-leak detector passes 3.0 gph test	8.5.1.2					
	Electronic line-leak detector passes 3.0 gph test	8.5.1.3					
	Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications	8.5.1.4					
	Submersible pump and visible piping and fittings show no signs of leaking	8.5.1.5					
	Piping in good condition	8.5.1.6					
	Submersible pump head, flex connector(s) and other metallic product piping are not in contact with soil or water or are cathodically protected	8.5.1.7					
	Any water or product removed and disposed of properly	8.5.2.1					
	Sump is free of cracks, holes, bulges, or other defects	8.5.3.1					
No STP Sump	Penetration fittings intact and secured	8.5.3.2					
	Piping interstitial space open to the sump (open piping system only)	8.5.3.3					
	Alarm sounds when pressure or vacuum is released (closed piping system only)	8.5.3.4.1					
	Entire interstitial space under pressure or vacuum (closed piping system only)	8.5.3.4.2					
	Sump sensor properly mounted at the bottom of the sump	8.5.3.4.3					
	Sensor tested and functional	8.5.3.5					

Appendix A-3: SAMPLE FORM FOR ANNUAL UNDERGROUND STORAGE SYSTEM INSPECTION CHECKLIST – PAGE 2

Go to www.pei.org/RP900 for an electronic version of this form

Category	Description	PEI/RP900	N/A	Tank 1	Tank 2	Tank 3	Tank 4
Other Tank-Top Sump	Sump lid, gasket, and seals present and in good condition	8.5.3.7					
	Manway cover at grade in good condition, does not touch sump cover, all bolts present, handles and lift mechanism in good condition (as applicable)	8.5.3.8					
		8.6					
	Any water or product removed and disposed of properly	8.5.3.1					
	Sump is free of cracks, holes, bulges, or other defects	8.5.3.2					
	Penetration fittings intact and secured	8.5.3.3					
	Piping interstitial space open to the sump (open piping system only)	8.5.3.4.1					
	Alarm sounds when pressure or vacuum is released (closed piping system only)	8.5.3.4.2					
	Entire interstitial space under pressure or vacuum (closed piping system only)	8.5.3.4.3					
	Sump sensor properly mounted at the bottom of the sump	8.5.3.5					
Other Tank-Top Sump (Same Procedure as STP Sump)	Sensor tested and functional	8.5.3.6					
	Sump lid, gasket, and seals present and in good condition	8.5.3.7					
	Manway cover at grade in good condition, does not touch sump cover, all bolts present, handles and lift mechanism in good condition (as applicable)	8.5.3.8					
		8.7					
	Any water or product removed and disposed of properly	8.5.3.1					
	Sump is free of cracks, holes, bulges, or other defects	8.5.3.2					
	Penetration fittings intact and secured	8.5.3.3					
	Piping interstitial space open to the sump (open piping system only)	8.5.3.4.1					
	Alarm sounds when pressure or vacuum released (closed piping system only)	8.5.3.4.2					
	Entire interstitial space under pressure or vacuum (closed piping system only)	8.5.3.4.3					
Other Sumps All Other Sumps (Same Procedure as STP Sump)	Sump sensor properly mounted at the bottom of the sump	8.5.3.5					
	Sensor tested and functional	8.5.3.6					
	Sump lid, gasket, and seals present and in good condition	8.5.3.7					
	Manway cover at grade in good condition, does not touch sump cover, all bolts present, handles and lift mechanism in good condition (as applicable)	8.5.3.8					
		8.8					
	Cap in good condition, seals tightly, hole sealed where probe wire goes through	8.8.1					
	ATC Manhole						

Appendix A-3: SAMPLE FORM FOR ANNUAL UNDERGROUND STORAGE SYSTEM INSPECTION CHECKLIST – PAGE 3

Go to www.pel.org/RP900 for an electronic version of this form

Category	Description	PEIRP900	N/A	Tank 1	Tank 2	Tank 3	Tank 4
	Wire splices sealed and wire in good condition	8.8.2					
	Junction box and conduit sealed, in good condition	8.8.3					
	Probe and floats in good condition, both floats present and move freely (mag probe)	8.8.4					
	Verify operation of water- and product-level warnings and alarms (mag probe)	8.8.5					
	Manhole cover in good condition, adequate clearance between the ATG probe cap and manhole cover	8.8.6					
Fill Area		8.9					
Drop Tube	Drop tube extends to within 6 inches of the tank bottom (if no flow diffuser present)	8.9.1					
Vapor Recovery Adaptor	Poppet of vapor-recovery adaptor (also known as a "dry break") moves freely, seals tightly	8.9.2					
Overflow Prevention		8.10					
Drop Tube (Flapper Valve)	Valve moves freely and operates according to manufacturer's specifications	8.10.1.1					
	Valve installed at proper height	8.10.1.2					
Ball-Float Valve	Ball float can be removed and inspected	8.10.2.1					
	Cage intact, ball in good condition, moves freely, seats firmly, breather hole open	8.10.2.2					
	Installed at proper height	8.10.2.3					
Overflow Alarm	Alarm mounted near fills, clearly labeled	8.10.3.1					
	Alarm is functional	8.10.3.2					
	Alarm sounds at the proper product level	8.10.3.3					
Leak Detection		8.11					
ATG Console	Console has no active warnings or alarms	8.11.1.1					
	Alarm history shows no recurring leak alarms	8.11.1.2					
	Verify in-tank leak-detection tests are being completed (if used for leak detection)	8.11.1.3					
	Verify correct set-up parameters for the in-tank test	8.11.1.4					
Continuous Interstitial Monitoring	Verify correct set-up parameters for electronic line-leak detector (if present)	8.11.1.5					
	Verify piping leak-detection tests are being completed (if used for leak detection)	8.11.1.6					
Tank Interstitial Access	Tank interstitial access is present	8.11.2.1					
	"Dry" tank sensor tested and functional, reinstalled at bottom of tank	8.11.2.2					

Appendix A-3: SAMPLE FORM FOR ANNUAL UNDERGROUND STORAGE SYSTEM INSPECTION CHECKLIST – PAGE 4

Go to www.pei.org/RP900 for an electronic version of this form

Category	Description	PEI/RP900	N/A	Tank 1	Tank 2	Tank 3	Tank 4
Electronic Leak-Detection Monitor	"Wet" tank sensor functional, reinstalled in proper position	8.11.2.3					
	"Wet" tank leak-detection liquid depth within range specified by manufacturer	8.11.2.4					
Line Tightness Testing	Leak-monitoring console is operational and has no active warnings or alarms	8.11.3.1					
	If pressurized piping has been tested in the last year, review the results and verify that the test passed If suction piping has been tested within the last three years, review the results and verify that the test passed.	8.11.4.1 8.11.4.2					
Under Piping Check Valve (Suction Pump)	Below grade piping operates at less than atmospheric pressure	8.11.5.1					
	Below grade piping slopes continuously back to the tank There is only one check valve, and it is located as close as practicable to the suction pump	8.11.5.2 8.11.5.3					
Tank Tightness Testing	If a tank test has been conducted within the last five years, review the results and verify that the test passed	8.11.6.1					
Continuous Soil-Vapor Monitoring	Sensing device calibrated and tested	8.11.7.1					
Continuous Groundwater Monitoring	Sensing device tested	8.11.8.1					
Corrosion Protection		8.12					
Galvanic CP	Verify that CP testing of all metallic components in contact with soil or water has been conducted within the past three years and test passed	8.12.1.1					
	Verify that CP testing has been conducted within the past three years and test passed	8.12.2.1					
Impressed Current CP	No exposed wires	8.12.2.2					
	Lining inspected as required and in good condition	8.12.3.1					
Miscellaneous		8.13					
Tank Pad & Coverment	Concrete or asphalt over or near tanks is level, no significant cracks	8.13.1.1					
	Cap in good condition, fits tightly, little or no liquid in bottom	8.13.2.1					
Stage I Testing	Verify that Stage II testing has been conducted and test results are passing	8.13.3.1					
	Site diagram accurately reflects the site conditions	8.13.4.1					
Initial Fuel Dispenser Inspection		8.14					
Initial Dispenser Inspection	All dispenser components are clean and dry	8.14.1.1					
	If fuel-dispenser sump is present, sump is dry	8.14.1.2					

Appendix A-3: SAMPLE FORM FOR ANNUAL UNDERGROUND STORAGE SYSTEM INSPECTION CHECKLIST – PAGE 5

Go to www.pei.org/RP900 for an electronic version of this form


Category	Description	PEI/RP900	N/A	Tank 1	Tank 2	Tank 3	Tank 4
Fuel Dispenser Inspection	Junction boxes sealed, not corroded; seal-offs present; intrinsically safe wiring in good condition	8.15					
All Dispensers	Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications	8.15.1.1					
	Piping in good condition	8.15.1.2					
Dispensers Without Sumps	Stage II piping functional or else capped and sealed at elevation lower than the fuel dispenser island	8.15.1.3					
	Flex connectors and other metallic product piping are not in contact with soil or water or are cathodically protected	8.15.1.4					
Dispensers With Sumps	Any water removed and disposed of properly	8.15.2.1					
	Sump free of trash, debris, and used filters	8.15.3.1					
	Sump is free of cracks, holes, bulges, or other defects	8.15.3.2					
Piping in Interstitial Space	Penetration fittings intact and secured	8.15.3.3					
	Piping interstitial space open to the sump	8.15.3.4					
Dispenser Sump Sensors	Sensor present in the fuel-dispenser sump with closed double-walled piping system	8.15.4.1					
	Sump sensor properly mounted at the bottom of the sump	8.15.4.2					
	Electronic sensor tested and functional	8.15.4.3					
Mechanical float sensor free to move and properly adjusted		8.15.5.1					
		8.15.5.2					
		8.15.5.3					

DESCRIBE ANY DEFICIENCIES HERE:

Instructions: Mark each tank where no problem is observed with a checkmark: ✓
 If certain equipment is not required and / or not present, mark checkmark in the N/A column.
 If a defect is found, mark the checklist with an "X," describe the problem in the "DEFICIENCIES" section, and notify the appropriate person.
 Refer to the section in the PEI Recommended Practices on UST system equipment inspection listed in the "PEI/RP900" column for additional information. Refer to PEI RP500, Recommended Practices for Inspection and Maintenance of Motor Fuel Dispensing Equipment, for inspection procedures that apply to fuel dispensing equipment.

Appendix A-4: SAMPLE SITE DIAGRAM FORM

Go to www.pei.org/RP900 for an electronic version of this form

Legend	Tanks	Piping	Site Diagram
ATG - automatic tank gauge CP - cathodic protection D - dispenser I - interstitial access DW - double wall F - fill STP - submersed turbine pump UST - underground storage tank V - vent connection VR - Stage I vapor recovery  - observation well			Facility Name: Address: Drawn by: Date:

See Figure 4-1 for an example of a completed form. Having ready access to accurate storage system information is very important to the proper operation of underground storage systems.

APPENDIX B

STORAGE SYSTEM INSPECTION SUMMARY TABLE			
COMPONENT	DAILY	MONTHLY	ANNUAL
Complete daily checklist and compare to previously completed daily checklists		X	
Complete monthly checklist and compare to previously completed monthly checklists			X
Automatic Tank Gauge	X	X	X
Check for Water In Tank		X	
Tank Top and Fuel Dispenser Sumps			X
Fuel dispensers			X
Drop Tube		X	X
Electronic Leak Detector		X	X
Fill Cover	X		
Fill Pipe	X	X	
Electronic Leak Detector (piping)		X	X
Galvanic Corrosion Protection			X
Tank Gauge Stick		X	
Grade Level Covers		X	
Groundwater/Soil Vapor Monitoring		X	X
Impressed Current Corrosion Protection		X	X
Inventory Control	X	X	
Leak Detection Monitor	X	X	X
Manual Interstitial Monitoring		X	
Mechanical Leak Detector (piping)	X		X
Observation Wells		X	X
Overfill Prevention			X
Piping Condition			X
Piping Leak Test		X	
Piping Tightness Test			X
Site Diagram			X
Spill Containment Manhole	X	X	
Stage I Vapor Recovery		X	X
Stage II Vapor Recovery			X
Statistical Inventory Reconciliation		X	
Submersible Turbine Pump			X
Tank Lining			X
Tank Pad and Pavement			X
Tank Tightness Test			X
Tank Vents		X	

TABLE B-1. This table lists alphabetically the components that are included in the daily, monthly, and annual inspections described in this recommended practice and the frequency of inspection for each of these components. Refer to the checklists in Appendix A and Chapters 6, 7, and 8 of this document for detailed descriptions of the inspection procedures.