



AIHENSIAI PRUTEKSION LINALA GUÅHAN
LOURDES A. LEON GUERRERO, GOVERNOR OF GUAM • JOSHUA F. TENORIO, LIEUTENANT GOVERNOR OF GUAM
WALTER S. LEON GUERRERO, ADMINISTRATOR

NOTICE OF VIOLATION GREASE TRAP

Notice of Violation issued to:

Control Number: WPC 2019-004

Business/restaurant name: BUGA RESTAURANT

Owner/manager name: LI, JINGJI

Email: _____ Phone: 747-5211

Mailing Address: P.O. BOX 25415 BAYUNGADA, GU 96921

Physical address/building name: 5142-3 TRACT 60 GRTC UNIT 26 & 26 HARMON INDUSTRIAL PARK

Description of Violation:

GEPA staff conducted an inspection of the premises described above and found the following deficiencies:

GREASE TRAP NEEDS TO BE CLEANED BY GEPA LICENSED COMPANY.

The facts described above indicate a violation of the Guam Individual Wastewater Disposal System Regulations, 22 GAR §12118(f): "In order to be effective, grease traps must be operated properly and cleaned regularly to prevent the escape of appreciable quantities of grease. The frequency of cleaning at any given installation can best be determined by experience based on observation. Generally, cleaning should be done when 75% of the grease- retention capacity has been reached. At restaurants, pumping frequencies range from once a week to once every 2 or 3 months."

Corrective Actions

Within 5 calendar days, complete the following corrective actions:

- Have the grease trap pumped by a GEPA licensed wastewater pumping company.
- Repair or replace the defective grease trap or grease trap component(s).
- Clean and disinfect the area where wastewater and grease was spilled.

If the corrective actions are not completed within the specified time, this matter may be referred to the Office of the Attorney General for appropriate action. Any person who violates this regulation may be charged with a misdemeanor and subject to a fine not to exceed \$1000 per violation per day.

Ongoing: you must maintain the grease trap by having it pumped at a frequency necessary to prevent further violations. Keep all pumping receipts and make them available for GEPA inspection upon request. You should keep all pumping receipts for a period of at least 12 months.

Inspector and Recipient Signature

Inspector Name: Helen Gumataog Title: INSPECTOR

Inspector Signature: [Signature]

Received by: [Signature] Date and time of inspection: 9/13/2019 11:58 AM

PRINT NAME AND SIGN

Questions regarding this matter should be referred to Guam EPA at 300-4751/52/53.