

APPENDIX B:

Guam Calendar Year 2022 Violations

YrMo	Qtr	PWS	SYSNAME	Viotype	Comments
<b>RTCR</b>					
2022	Q1-Q4	GU0000003	GUAM WATERWORKS AUTHORITY	MCL E. coli	Routine sample collected on April 26, 2022 at Ghura Southwest Site Base Office located in the village of Agat tested both TC and EC positive. The repeat sample collected on April 27, 2022 at the same location along with the upstream and downstream locations tested was positive for total coliform but negative E. coli. This represents a violation of the maximum contaminant level (MCL) for E. coli. The GWA Central Water System has achieved the Compliance Order and has returned to compliance.

